



# Certificate of constancy of performance 0063-CPR-0217357-1



Issued 2024-05-01 Replaces -  
First issued 2024-05-01 Page 1 of 3

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Underground fire hydrants

**Type and intended use:** EN 14339: Underground fire hydrants  
**Level / Class:** Not applicable  
**Method of declaration:** EN 14339: Underground fire hydrants  
**Other Characteristics:** Described on page 2

placed on the market under the name or trademark of

### Torshälla Industrisvets AB

and produced in the manufacturing plant

### Torshälla Industrisvets AB, Torshälla, Sweden

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

#### EN 14339:2005

Under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 1 May 2024 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product and the manufacturing conditions in the plant or the factory production control itself are not modified.

Ron Scheepers  
Managing director  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

#### Manufacturer

Torshälla Industrisvets AB  
Saxgatan 8  
644 30 Torshälla  
Sweden  
Tel +46 016-34 66 60  
info@thisab.com  
www.thisab.com

#### Manufacturing plant

Torshälla Industrisvets AB  
Saxgatan 8  
644 30 Torshälla  
Sweden  
Tel +46 016-34 66 60  
info@thisab.com  
www.thisab.com

Notified Body No. 0620



---

Notified Body No.0063, Kiwa

## Certificate of constancy of performance 0063-CPR-0217357

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Underground hydrants

Type of product:	Type BP 1990T	Type BP 2001T
Size outlet	DN 100	DN 100
Size inlet	DN 100	DN 100
Pressure	PN 10	PN 10

---

## Marking

Compulsory specifications:

### EN 14339, underground hydrants

- Indication of direction of opening;
- Number of turns required to start the flow and for full opening;
- Indication of DN;
- Indication of PN;
- Name or logo of the manufacturer;
- Date or code indicating the year of production;
- Reference to the applicable standard (EN 14339);
- Loose obturator (if applicable).

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

Application and use

The hydrants are intended for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 30°C.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Torshälla Industrisvets AB
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.